2号炉 燃焼ガス温度及び集じん器入口ガス温度ならびに煙道入口CO濃度(R5年度)

	燃焼ガス温度(℃)	集じん器入口ガス温度(°C)	排ガスCO濃度(PPM)
4月	1007	163	8.0
5月	996	161	0.8
6月	993	161	0.7
7月	1067	164	1.2
8月	1063	161	1.0
9月	950	158	1.0
10月	1028	165	0.7
11月	-	-	-
12月	1077	162	0.9
1月	1060	160	0.9
2月	1038	160	1.0
3月	1043	160	1.3

[※] 炉運転時の連続測定記録についてはネット上での掲載が困難な為、月平均値を記載(KCSでの閲覧は可能)

2号炉 集じん器及びボイラーのばいじん除去状況(○印 溶融炉運転日連続排出)

	1	2	3	4	5	6	7	8	9	10	11	12	13	14	15	16	17	18	19	20	21	22	23	24	25	26	27	28	29	30	31
4月	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	
5月	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0
6月	0	0	0	0	0	0	0	0	0	0	0			0	0	0	0	0	0	0	0	0	0	0	0	0	0				
7月	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0
8月	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0								
9月																													0	0	
10月	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0						
11月																															
12月																		0	0	0	0	0	0	0	0	0	0	0	0	0	0
1月	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0
2月	0	0	0	0	0	0	0	0	0				0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0		
3月	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0